



## 1. ELECTRICAL SPECIFICATIONS

Accuracy indicated as  $\pm$  [% readings + (number of digits \* resolution)] at 23 °C  $\pm$  5 °C <80%HR

### Continuity of protection conductor with I>200mA

Range ( $\Omega$ )	Resolution ( $\Omega$ )	Accuracy	Overload protection
0.00 $\div$ 19.99	0.01	$\pm(3.0\%rdg + 3dgt)$	CAT III 300V
20.0 $\div$ 199.9	0.1		

Standard test leads: cables 2.5mmq, 2m length  
 Output voltage: approx. 4.5V AC  
 Test current: >200mA DC (R < 20 $\Omega$  with standard test leads)  
 Timer on measure: 1s  $\div$  60min (in step of 1s)  
 Measure method: 2 wires

### Continuity of protection conductor with I>25A (2-wire)

Range ( $\Omega$ )	Resolution ( $\Omega$ )	Accuracy	Overload protection
0.000 $\div$ 1.999	0.001	$\pm(3.0\%rdg + 3dgt)$	CAT III 300V
2.00 $\div$ 19.99	0.01		

Standard test leads: cables 2.5mmq, 2m length  
 Output voltage: approx. 4.5V AC  
 Test current: > 25A AC (R < 0.1 $\Omega$  with standard test leads)  
 >10A AC (R < 0.5 $\Omega$  with standard test leads)  
 Timer on measure: 1s  $\div$  60min (in step of 1s)  
 Measure method: 2 wires

### Continuity of protection conductor with I>25A (4-wire)

Range ( $\Omega$ )	Resolution ( $\Omega$ )	Accuracy	Overload protection
0.000 $\div$ 1.999	0.001	$\pm(3.0\%rdg + 3dgt)$	CAT III 300V
2.00 $\div$ 19.99	0.01		

Standard test leads: cables 2.5mmq, 2m length  
 Output voltage: approx. 4.5V AC  
 Test current: > 25A AC (R < 0.1 $\Omega$  with standard test leads)  
 >10A AC (R < 0.5 $\Omega$  with standard test leads)  
 Timer on measure: 1s  $\div$  60min (in step of 1s)  
 Measure method: 4 wires

### Continuity of protection conductor with – IEC/EN60204-1:2006

Range ( $\Omega$ )	Resolution ( $\Omega$ )	Accuracy	Overload protection
0.000 $\div$ 1.999	0.001	$\pm(3.0\%rdg + 3dgt)$	CAT III 300V
2.00 $\div$ 19.99	0.01		

Standard test leads: cables 2.5mmq, 2m length  
 Line impedance range: 0.001 $\Omega$   $\div$  2.000 $\Omega$  (in step of 0.001 $\Omega$ )  
 Section of PE conductor: 1, 2.5, 4, 6, 10, 16, 25, 35, 50, 70mmq  
 Type of protection devices: MCB (magnetothermic) Curve B, C, D, K, Fuses type gG, aM  
 Nominal current MCB: 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A (Curve B)  
 0.5, 1, 1.6, 2, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A (Curve C)  
 0.5, 1, 1.6, 2, 4, 6, 10, 13, 16, 20, 25, 32A (Curve D and Curve K)  
 Nominal current fuse: 2A  $\div$  1250A (Fuse gG) ; 2A  $\div$  6300A (Fuse aM)  
 Cable length range: 0.1  $\div$  999.9m  
 Type of cable selectable: Copper, Aluminum  
 Output voltage: approx. 4.5V AC  
 Test current: >10A AC  
 Timer on measure: 1s  $\div$  60min (in step of 1s)  
 Measure method: 4 wires



## Insulation resistance

Test voltage (V)	Range (MΩ)	Resolution (MΩ)	Accuracy	Overload protection
100	0.01 ÷ 9.99	0.01	±(3.0%rdg+3dgt)	CAT III 300V
	10.0 ÷ 19.9	0.1		
	20.0 ÷ 99.9		±5.0%rdg	
250	0.01 ÷ 9.99	0.01	±(3.0%rdg+3dgt)	
	10.0 ÷ 19.9	0.1	±5.0%rdg	
	20.0 ÷ 99.9			
	100 ÷ 249	1		
500	0.01 ÷ 9.99	0.01	±(3.0%rdg+3dgt)	
	10.0 ÷ 19.9	0.1	±5.0%rdg	
	20.0 ÷ 99.9			
	100 ÷ 499	1		
1000	0.01 ÷ 9.99	0.01	±(3.0%rdg+3dgt)	
	10.0 ÷ 19.9	0.1	±5.0%rdg	
	20.0 ÷ 99.9			
	100 ÷ 999	1		

Nominal test voltage: 100, 250, 500, 1000VDC  
 Accuracy test voltage: (-0% ÷ 25%) Unom  
 Test current: > 1mA (fino a Unom/1mA)  
 Short circuit current: <15mA  
 Measurement modes: Manual, Auto, Timer  
 Timer on measure: 5s÷10min (resolution 1s)

## Dielectric test

Nominal test voltage Un (V)	Resolution (V)	Accuracy	Overload protection
250 ÷ 800	10	±3.0%Un	CAT III 300V
810 ÷ 2500			
2510 ÷ 5100			

Test voltage: 250V ÷ 5100V AC, 50/60Hz programmable in steps of 10V  
 Measurement modes: MANUAL, RAMP, TIMER, BURN  
 PULSE: (duration 3 measurement cycles: 60ms@50Hz, 50ms@60Hz)  
 Timer on measure: 1s ÷ 10min in step of 1s  
 Output power: 500VA at 5100V  
 Discharging current: selectable IAPP and IREAL modes

## Discharging current IAPP mode

Measurement range (mA)	Resolution (mA)	Accuracy	Overload protection
0 ÷ 200	1	±3.0%rdg + 2mA	CAT III 300V

## Discharging current IREAL mode

Measurement range (mA)	Resolution (mA)	Accuracy	Overload protection
0 ÷ 110	1	±3.0%rdg + 4mA	CAT III 300V

Discharging current threshold: 1 ÷ 110mA (adjustable in step of 1mA, for IAPP or IREAL modes)  
 Short circuit current: > 200mA

## Residual voltage – Modes INT and PLUG

Range (s)	Resolution (s)	Accuracy	Overload protection
10 ÷ 460 V AC	1	±(3.0%rdg + 3V)	CAT III 300V
10 ÷ 650 V DC			

Nominal main voltage: 230V o 240V  
 Input voltage (UTRIG): 0 ÷ 460V V AC  
 Measurement modes: INT (4 wire connection, discharging time 1s or 5s, Linear, Not Linear)  
 PLUG (2 wire connection, discharging time 1s, Linear, Not Linear)  
 Limit value residual voltage: 60V TRMS  
 Range AC voltage: 0.0 ÷ 710V  
 Input impedance: 100MΩ (URES), 450kΩ (UTRIG)



## Leakage current on the test socket

Range	Resolution	Accuracy	Overload protection
0.25mA ÷ 49.99mA	0.01mA	±(3.0%rdg + 3dgt)	CAT II 300V
0.05A ÷ 0.99A	0.01A		
1.0A ÷ 10.0A	0.1A		

Power supply: 195V ÷ 253V AC  
 Frequency range: 40Hz ÷ 100kHz  
 Limit value: 0.25mA ÷ 10.00mA selectable

## Absorbed current on test socket

Range (A)	Resolution (A)	Accuracy	Overload protection
0.00 ÷ 0.99	0.01	±(3.0%rdg + 3dgt)	CAT II 300V
1.0 ÷ 20.0	0.1		

Power supply: 195V ÷ 253V AC  
 Frequency range: 15Hz ÷ 723Hz

## Active / Apparent power on test socket

Range (W/VA)	Resolution (W/VA)	Accuracy	Overload protection
0.0 ÷ 99.9	0.1	±(5.0%rdg + 10dgt)	CAT II 300V
100 ÷ 999	1	±(5.0%rdg + 3dgt)	
1.00k ÷ 5.06k	10		

Power supply: 195V ÷ 253V AC  
 Frequency range: 15Hz ÷ 723Hz  
 Timer: 5s ÷ 60min (resolution 1s)  
 Limit value apparent power: 6VA ÷ 5.06kVA

## Power factor

Range	Resolution	Accuracy	Overload protection
0.00 ÷ 1.00	0.01	See Papp, Pact	CAT II 300V

## Leakage current with external transducer clamp HT96U (optional accessory)

Selectable range	Measurement range	Resolution	Accuracy (*)	Overload protection
1A	0.0 ÷ 99.9mA	0.1mA	±(3.0%rdg + 3dgt)	Measurement lead connected to ground
	100mA ÷ 1000mA	1mA		
100A	0.00A ÷ 9.99A	0.01A		
	10.0A ÷ 100.0A	0.1A		
1000A	0.0A ÷ 99.9A	1A		
	100A ÷ 1000A			

(\*) Accuracy of instrument without clamp  
 Type of clamp: HT96U optional accessory (available ranges 1A, 100A, 1000A)  
 Transduced input voltage: 0 ÷ 1V AC  
 Input impedance: 1MΩ  
 Frequency range: 40Hz ÷ 100kHz



## RCD Test

Nominal currents selectable:	10mA, 30mA, 100mA, 300mA, 500mA, 650mA, 1000mA
Type RCD:	AC, A, B, General, Selective, Delayed
Measurement modes:	x1/2, x1, x2, xK (K= 4 B type, K=5 AC, A type), Ramp, Auto (seq:x1/2, x1, xK), Ut
Range voltage / frequency:	100V ÷ 265V / (50Hz/60Hz) ±0.5Hz
Contact voltage limits:	25V, 50V selectable
Test current polarity:	0°, 180° selectable

**During of trip out test [ms] – TT/TN systems** (Resolution:1ms, Accuracy: ±(3.0%rdg+ 2ms)

	x 1/2			x1			x2			xK			AUTO			Rampa		
	G	S	R	G	S	R	G	S	R	G	S	R	G	S	R	G	S	R
<b>10mA</b> <b>30mA</b> <b>100mA</b>	AC	1000	1000	1000	1000	1000	1000	1000	1000	200	250	50	150	✓	✓	320		
	A	1000	1000	1000	1000	1000	1000	1000	1000	200	250	50	150	✓	✓	320		
	B	1000	1000	1000	1000	1000	1000	1000	1000			200	250	✓	✓	320		
<b>300mA</b>	AC	1000	1000	1000	1000	1000	1000	1000	1000	200	250	50	150	✓	✓	320		
	A	1000	1000	1000	1000	1000	1000	1000	1000	200	250	50	150	✓	✓	320		
	B	1000	1000	1000	1000	1000	1000	1000	1000							320		
<b>500mA</b>	AC	1000	1000	1000	1000	1000	1000	1000	1000	200	250	50	150	✓	✓	320		
	A	1000	1000	1000	1000	1000	1000	1000	1000	200	250					320		
	B	1000	1000	1000												320		
<b>650mA</b>	AC	1000	1000	1000	1000	1000	1000	1000	1000	200	250	50	150	✓	✓	320		
	A	1000	1000	1000	1000	1000	1000	1000	1000	200	250					320		
	B															320		
<b>1000mA</b>	AC	1000	1000	1000	1000	1000	1000	1000	1000	200	250					320		
	A	1000	1000	1000	1000	1000	1000	1000	1000							320		
	B															320		

## Line / Loop Impedance P-P, P-N, P-PE

Range (Ω)	Resolution (Ω)	Accuracy	Overload protection
0.000 ÷ 2.000 (*)	0.1m	±(3.0%rdg + 3dgt)	CAT III 300V
0.00 ÷ 9.99	0.01		
10.0 ÷ 99.9	0.1		
100 ÷ 199	1		

(\*) Only with optional accessory IMP57

Measurement modes:	Loop/lpsc, kA, I2t test, trip current , Ut (indirect contact)
Type of protection devices:	MCB (magnetothermic) Curve B, C, D, K, Fuse type gG, aM
Corrente nominale MCB:	6, 10, 13, 16, 20, 25, 32, 40, 50, 63A (Curve B) 0.5, 1, 1.6, 2, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A (Curve C) 0.5, 1, 1.6, 2, 4, 6, 10, 13, 16, 20, 25, 32A (Curve D and Curve K)
Nominal current fuses:	2A ÷ 1250A (Fuse gG) ; 2A ÷ 6300A (Fuse aM)
Breakdown current MCB/Fuses::	1kA ÷ 25kA selectable
Section of cable:	1 ÷ 70mmq selectable
Cable type:	Copper, Aluminum
Type of cable insulation:	PVC, Butyl rubber, EPR/XLPE
Number of parallel cables (I2t test):	1 ÷ 99
Trip out time of protection devices:	0.1s, 0.2s, 0.4s, 5s
P-N, P-PE / P-PP voltage:	100 ÷ 265V / 100 ÷ 460V
Frequency:	(50Hz/60Hz) ±0.5Hz

## Prospective short circuit current (Ipsc)

Range (A)	Resolution (A)	Accuracy	Overload protection
0.05 ÷ 0.99	0.01	Depending on the accuracy of Z measure	CAT III 300V
1.0 ÷ 99.9	0.1		
100 ÷ 999	1		
1.00k ÷ 46.00k	0.01k		

**Global earth resistance without RCDs tripping**

Idn (mA)	Measure range ( $\Omega$ )	Resolution ( $\Omega$ )	Accuracy	Overload protection
10	0 ÷ 1999	1	$\pm(3.0\%rdg + 1\Omega)$	CAT III 300V
30	0.0 ÷ 99.9	0.1		
	100 ÷ 1999	1		
100	0.0 ÷ 99.9	0.1	$\pm(3.0\%rdg + 3dgt)$	
	100 ÷ 999	1		
300	0.0 ÷ 99.9	0.1		
	100 ÷ 299	1		
500	0.0 ÷ 99.9	0.1		
	100 ÷ 199	1		
650	0.0 ÷ 99.9	0.1		
	100 ÷ 149	1		
1000	0.0 ÷ 99.9	0.1		

Test current:  $I_{dn}/2$   
P-N, P-PE / P-PP voltage: 100 ÷ 265V, 50/60Hz  
Mains nominal voltage: 230V or 240V

**Contact voltage**

Range (V)	Resolution (V)	Accuracy	Overload protection
0 ÷ 100 (U <sub>tlim</sub> = 50V)	1	$\pm(3\%rdg + 3V)$	CAT III 300V
0 ÷ 50 (U <sub>tlim</sub> = 25V)			

**Phase sequence rotation test**

Range (V)	Frequency	Overload protection
360 ÷ 460	50Hz/60Hz $\pm 0.5Hz$	CAT III 300V

Indication of test: 1.2.3. (correct), 2.1.3. (incorrect), 1.1.X (not defined)



## 2. GENERAL SPECIFICATIONS

### POWER SUPPLY:

Main voltage:	207V ÷ 253V AC - 50/60Hz ±5%
Absorbed current:	16Amax

### MECHANICAL SPECIFICATIONS:

Dimensions (L x W x H):	400 x 300 x 170mm
Weight:	15kg

### MEMORY AND INPUT/OUTPUT INTERFACES

Internal memory:	999 locations (three levels structure)
PC interface:	USB type "B"
Keyboard, printer, pen drive, barcode:	2 x USB type "A"
Warning lamp:	for Dielectric test
Keyboard for remote controls	START/STOP/SAVE keys
Bluetooth interface	connection to mobile devices

### ENVIRONMENTAL CONDITIONS:

Reference temperature:	23°C ± 5°C
Working temperature:	0°C ÷ 40°C
Working humidity:	<80%HR
Storage temperature:	-10 ÷ 60°C
Storage humidity:	<80%HR

### REFERENCE GUIDELINES

Safety tests machines/switchboards/devices:	IEC/EN60204-1; IEC/EN61439-1-2; IEC/EN60335-1
Literature:	IEC/EN61187
Instrument:	IEC/EN61557-1-2-3-4-6-13-14

### GENERAL CHARACTERISTICS:

Display :	TFT, LCD, color 4.3" with capacitive touch screen
Instrument safety:	IEC/EN61010-1
Insulation:	double insulation
Pollution degree:	2
Measurement category:	CAT II 300V (I, Leak, Power), CAT III 300V (other tests)
Max. height of use:	2000m
Mechanical protection:	IP40
Input protections:	Fuses T16/250V, FF12.5A/500V, F20A/500V

**This instrument complies with the requirements of the European Low Voltage Directives 2014/35/EU (LVD) and EMC 2014/30/EU**

**This instrument satisfies the requirements of 2011/65/EU (RoHS) directive and 2012/19/EU (WEEE) directive**



# Services d'EURO-INDEX

EURO-INDEX est un fabricant, importateur et distributeur de diverses marques A dans le domaine des instruments de test et de mesure. Nous fournissons également une large gamme de services pour optimiser l'utilisation de ces instruments dans vos activités. Ces services comprennent naturellement l'entretien, la réparation et l'étalonnage des instruments, mais nous proposons aussi une assistance sous forme de formation via notre EURO-INDEX Academy et la location d'instruments.

## Centre de Service Agréé

EURO-INDEX est un Centre de Service Agréé pour toutes les marques représentées. Cela signifie que vos instruments sont pris en charge par des techniciens formés par le fabricant et disposant des outils et logiciels adéquats. Seules des pièces d'origine sont utilisées et la garantie de votre instrument, ainsi que les certifications (ATEX, EN50379, etc.) restent intactes.

## Laboratoire de maintenance et de calibrage

Le laboratoire des Pays-Bas est accrédité RvA selon la norme EN-ISO/IEC 17025. Cette accréditation est valable pour différentes grandeurs, telles que spécifiées dans le champ d'application associé au numéro d'accréditation K105. Les certificats de calibrage RvA sont acceptés à l'international et équivalents à ceux de BELAC.



## Service Mobile

Outre les laboratoires d'étalonnage fixes de Zaventem et de Capelle aan den IJssel, nous disposons également d'un laboratoire itinérant appelé "Service mobile". Nos services peuvent venir vers vous, en offrant une qualité équivalente.

## MQS®

MQS® est une formule d'entretien exclusive comportant un entretien et un calibrage périodiques de vos instruments de mesure à un coût fixe et faible. Via un portail Web gratuit ([monmq.be](http://monmq.be)), vous avez toujours accès à vos certificats de calibrage.

## Location d'instruments de mesure

- Vaste assortiment
- Précision démontrable par le certificat d'étalonnage actuel
- Conseils avisés
- Les instruments sont livrés avec leurs accessoires

## EURO-INDEX Academy

- Formations et séminaires
- Vidéos de démonstration et d'instruction
- Notes d'application



Comptoir de service



Entretien, réparation et calibrage



Formations et séminaires



Service Mobile

Sous réserve de modifications EURO-INDEX® FR 23001



**BELGIQUE**  
Chaussée de Louvain 607  
1930 Zaventem  
T: 02 - 757 92 44  
F: 02 - 757 92 64  
[sales@euro-index.be](mailto:sales@euro-index.be)  
[www.euro-index.be](http://www.euro-index.be)

**PAYS-BAS**  
Rivium 2e straat 12  
2909 LG Capelle a/d IJssel  
T: +31 - (0)10 - 2 888 000  
F: +31 - (0)10 - 2 888 010  
[verkoop@euro-index.nl](mailto:verkoop@euro-index.nl)  
[www.euro-index.nl](http://www.euro-index.nl)

