



ARGB – KVBG

The ARGB-KVBG laboratory certifies the conformity with the Belgian requirements for ball gas valves with MOP \leq 5 bar

Certificate number: C-14-3651-A

Date of issue: 20-03-2014

Fabricant: **IVR S.p.A.**
Manufacturer: Via Brughiera III, 1 – Loc. Piano Rosa
Fabrikant: IT-28010 BOCA (NO)
ITALY

Vanne Type:
Valve Model: **Gas ball valve IVR 192 Elite (DN15 - DN20 - DN25)**
Kraan Type:

Exigences belges:
Belgian Requirements:
Belgische eisen:

• Comply with the standard EN 331 “Manually operated ball valves and closed bottom taper plug valves for gas installations for buildings”
Certificate INIG CE 1450-CPR-1010 dd 03.03.2014
- test report INIG nr 1/GP/2014 from 24.02.2014

• Comply with the high temperature resistance according to EN 1775 annex A clause B
Test report ARGB nr 12-3602-A from 18.12.2012
Test report ARGB nr 13-3608-A from 21.02.2013.


Hilde VINCK.
Laboratory Manager