

# tSENSE (Disp)



## CO<sub>2</sub>, Temperature and RH Sensor with colour touch display

tSENSE is an advanced and versatile 3-in-1 sensor designed for installation in the air-conditioned zone. It measures CO<sub>2</sub> concentration, temperature and humidity in the ambient air accurately without need for additional compensation – true read. The data transmits to a BMS system or stand-alone controller using industry standard output signals and communication protocols.

tSENSE combines all the necessary elements for effective climate control in commercial office buildings, hospitals, hotels, schools and other facilities. Using CO<sub>2</sub>-monitoring for demand control ventilation (DCV) allows healthy, comfortable and cost-effective environment for the occupants.

tSENSE is flexible in design with temperature control in combination with humidity control optional. Though suitable for use in many different energy-efficient ventilation strategies, Senseair welcomes any discussions for specific needs.

Complies with ASHRAE standard 189.1  
(±50ppm @ 1000ppm of measured CO<sub>2</sub> value)

## Standard specification

|                             |   |
|-----------------------------|---|
| Measured gas                | Carbon dioxide (CO <sub>2</sub> )                         |
| Operating principle         | Non-dispersive infrared (NDIR)                            |
| Measurement range           | 0–2000ppm   |
| OUT1 CO <sub>2</sub>        | 0–10VDC, 0–2000ppm  |
| OUT2 Temperature            | 0–10VDC, 0–50°C   |
| OUT3 Relative Humidity      | 0–10VDC, 0–100%RH   |
| Relay CO <sub>2</sub>       | On ≥1000 ppm <sub>vol</sub><br>Off ≤900ppm <sub>vol</sub> |
| Accuracy (CO <sub>2</sub> ) | ±30 ppm ±3% of reading                                    |
| Dimensions [mm]             | 125 x 85 x 22   |
| Dimensions display [mm]     | 49 x 37   |
| Life expectancy             | >15 years   |
| Operation temperature range | 0–50°C  |
| Power supply                | 12VDC, 24VAC/DC   |
| Communication               | Modbus (MB) or BACnet (BAC) protocol over RS485           |

## Key benefits

- Maintenance free
- Three sensors in one housing: CO<sub>2</sub>, temp and RH
- Colour touch display with possibility of customisable GUI
- PIN codes for access to display and meter settings
- Improved housing design for effective measurement



**Senseair**

©2019 Senseair AB. All rights reserved.

# tSENSE (Disp) Technical Specification

## General Performance:

|                                   |   |
|-----------------------------------|---|
| Storage Temperature Range         | -30–70°C  |
| Sensor Life Expectancy            | >15 years   |
| Maintenance Interval <sup>1</sup> | Maintenance free  |
| Self-Diagnostics                  | Complete function-check of the sensor module  |
| Display (Disp)                    | Configurable colour LCD with CO <sub>2</sub> [ppm], Temperature [°C] and Humidity [%RH] |
| Buttons                           | Touch display (Disp)  |
| Warm-up Time                      | ≤1min.(@ full specs 15min )   |
| Operating Temperature Range       | 0–50°C  |
| Operating Humidity Range          | 0–95%RH, non condensing humidity environment  |
| Operating Environment             | Residential, commercial   |

## Electrical / Mechanical:

|                        |   |
|------------------------|---|
| Power Input            | 12VDC, 24VDC or 24VAC (50–60Hz) ±20%  |
| Power Consumption      | <0.35W average non-display version, <0.6W display version   |
| Peak Power Consumption | <2W   |
| Wiring Connections     | Screw terminal, max 1.5mm <sup>2</sup> , Containing: Power, GND, Out1, Out2, Out3, RS485.<br>Option: passive temperature or relay |

## CO<sub>2</sub> Measurement:

|                       |  |
|-----------------------|--|
| Sensing Method        | Non-dispersive infrared (NDIR) waveguide technology  |
| Sampling Method       | Diffusion  |
| Response Time (T1/e)  | <3min  |
| Measurement Range     | 0–2000ppm <sub>vol</sub>   |
| Accuracy <sup>2</sup> | ±50ppm (@1000ppm <sub>vol</sub> , 17–28°C and 30–60%RH)<br>Typical full range: ±30ppm +3% of measured value <sup>3,4</sup> |
| Pressure Dependence   | +1.58% reading per kPa deviation from normal pressure, 101.3kPa  |
| Measurement Interval  | 15s  |

## Temperature Measurement:

|                       |   |
|-----------------------|---|
| Measurement Range (T) | 0–50°C                                      |
| Accuracy <sup>5</sup> | ±0.5°C (@ 17–28°C), ±1.0°C (outside 0–50°C) |
| Repeatability         | ±0.25°C (@ 17–28°C)                         |
| Response Time         | <6min (Air velocity of 0.15m/s)             |
| Measurement Interval  | 15s   |

## Relative Humidity Measurement:

|                       |                                 |
|-----------------------|---------------------------------|
| Measurement Range     | 0–100%RH                        |
| Accuracy <sup>5</sup> | ±5%RH (@ 20–80%RH)              |
| Hysteresis            | ±1%RH (@ 20–80%RH)              |
| Annual Drift          | <±0.5%RH                        |
| Repeatability         | ±0.25%RH (@ 17–28°C)            |
| Response Time         | <6min (Air velocity of 0.15m/s) |
| Measurement Interval  | 15s                             |

## Outputs:

### Linear Analog Outputs:

|   |   |
|---|---|
| Protection                                | PTC-fuses (auto reset), short-circuit safe                          |
| Output Conversion Accuracy                | ±2% of reading ±20mV  |
| Output Signal                             | Voltage output 0–10V, Rout <100Ω, Load: >5kΩ                        |
| Output Resolution                         | 10-bits, 10mV steps, 0.1% steps of full ppm/°C/%RH range            |
| Out1: CO <sub>2</sub> <sup>6</sup>        | 0–10V, corresponds to 0–2000 ppm <sub>vol</sub> , at screw terminal |
| Out2: Temperature (T) <sup>7</sup>        | 0–10V, corresponds to 0–50°C, at screw terminal                     |
| Out3: Relative Humidity (RH) <sup>7</sup> | 0–10V, corresponds to 0–100%RH, at screw terminal                   |

### Digital Output:

|                         |  |
|-------------------------|--|
| Relay (RL) <sup>6</sup> | On ≥1000 ppm <sub>vol</sub> CO <sub>2</sub> , Off ≤900ppmv <sub>ol</sub> , CO <sub>2</sub> , at screw terminal |
| Input Source            | Form C / DPDT, I <sub>max</sub> : 1A/50VAC/24VDC<br>CO <sub>2</sub> / T / RH (configurable via touch display)  |

Note 1: No maintenance required in normal indoor air as ABC (Automatic Baseline Correction) is used.

Note 2: In normal IAQ applications, accuracy is defined after minimum three (3) ABC-periods of continuous operation with ABC.

Note 3: Accuracy is specified over operating temperature range. Specification is referred to certified calibration mixtures. Uncertainty of calibration gas mixtures (±1% currently) is to be added to the specified accuracy for absolute measurements.

Note 4: Repeatability is included. Uncertainty of calibration gases (±1%) is added to the specified accuracy.

Note 5: Depending on display brightness setting.

Note 6: Can be configured with PC software UIP (version 5 or later). See information at [senseair.com](http://senseair.com)

# Les services d'EURO-INDEX

EURO-INDEX fournit des services pour tous les instruments de sa gamme de fournitures et offre des services, de la connaissance et du personnel hautement qualifié pour l'entretien (préventif), la réparation et le calibrage de vos instruments de mesure.

## Centre de Service Agréé.....

EURO-INDEX est un Centre de Service Agréé pour toutes les marques représentées.

Autrement dit, vos instruments sont traités par du personnel formé et compétent, qui dispose des outils et logiciels adéquats. Seules des pièces d'origine sont utilisées et la garantie de votre instrument ainsi que la certification (ATEX, EN50379, etc.) restent valables.

## Laboratoire de maintenance et de calibrage .....

EURO-INDEX dispose d'un laboratoire de maintenance et de calibrage particulièrement moderne, titulaire d'une accréditation conforme à la norme NEN-EN-ISO/IEC 17025. Cette accréditation est valable pour différentes grandeurs, telles que spécifiées dans le champ d'application associé au numéro d'accréditation K105.



## MQS® .....

MQS est une formule d'entretien exclusive comportant un entretien et un calibrage périodiques de vos instruments de mesure. La prise en charge de multiples aspects vise à vous libérer de tout souci lors de l'utilisation de vos instruments de mesure. Les coûts sont modiques et prévisibles.

## Accès numérique à vos certificats de calibrage avec Mon MQS .....

Mon MQS est un portail Web qui vous donne accès partout et à tout moment à vos certificats de calibrage et aux documents apparentés.

## Location d'instruments de mesure .....

- Vaste assortiment
- Conseils avisés
- Les instruments sont livrés avec leurs accessoires et leurs certificats de calibrage traçables

## EURO-INDEX Academy .....

- Formations sur les produits (individuelles et collectives)
- Séminaires
- Vidéos de démonstration et d'instruction

**Visionnez la vidéo sur notre chaîne YouTube et découvrez tout ce qu'il vous faut savoir sur MQS**



Guichet des services



Calibrage de l'analyse de gaz de combustion



Séminaires et ateliers



Calibrage de la thermographie

Sous réserve de modifications EURO-INDEX® FR 18001

Le nom et la marque Bluetooth® sont la propriété de Bluetooth SIG Inc. L'utilisation de ce nom par EURO-INDEX s'effectue sous licence.



**BELGIQUE**  
Leuvensesteenweg 607  
1930 Zaventem  
T: 02 - 757 92 44  
F: 02 - 757 92 64  
info@euro-index.be  
www.euro-index.be

**PAYS-BAS**  
Rivium 2e straat 12  
2909 LG Capelle a/d IJssel  
T: +31 - (0)10 - 2 888 000  
F: +31 - (0)10 - 2 888 010  
verkoop@euro-index.nl  
www.euro-index.nl

